



# Puget Sound Clean Air Agency

Notice of  
Construction No. 9769  
Registration No. 11339

HEREBY ISSUES AN ORDER OF APPROVAL  
TO CONSTRUCT, INSTALL, OR ESTABLISH

Date  
FEB 12 2008

Replacement of clinker/gypsum conveyor (511.BC5).

## APPLICANT

Gerald Brown  
Ash Grove Cement Co, E Marginal  
3801 E Marginal Way S  
Seattle, WA 98134

## OWNER

Ash Grove Cement Co, E Marginal  
3801 E Marginal Way S  
Seattle, WA 98134

## INSTALLATION ADDRESS

Ash Grove Cement Co, E Marginal, 3801 E Marginal Way S, Seattle, WA, 98134-1113

## THIS ORDER IS ISSUED SUBJECT TO THE FOLLOWING RESTRICTIONS AND CONDITIONS

1. Approval is hereby granted as provided in Article 6 of Regulation I of the Puget Sound Clean Air Agency to the applicant to install or establish the equipment, device or process described hereon at the INSTALLATION ADDRESS in accordance with the plans and specifications on file in the Engineering Division of the Puget Sound Clean Air Agency.
2. This approval does not relieve the applicant or owner of any requirement of any other governmental agency.
3. The new clinker/gypsum conveyor is subject to 40 CFR Part 60, Subparts F and A.
4. There shall be no visible emissions or fallout from the new clinker/gypsum conveyor and baghouses.
5. Each baghouse shall be equipped with a gauge to measure the pressure drop across the filters. The acceptable range shall be clearly marked on or near the gauge within 90 days of initial startup.
6. Ash Grove Cement shall record the pressure drop across the filters during each shift when the baghouse is in operation. If the pressure drop across the exhaust filters of the baghouse is not within the acceptable range, Ash Grove Cement shall take corrective actions within 24 hours in accordance with the O&M Plan or cease operation of the equipment until the problem is repaired. Ash Grove shall maintain records of these corrective actions on site for at least two years and make them available to Puget Sound Clean Air Agency personnel upon request.

## APPEAL RIGHTS


Pursuant to Puget Sound Clean Air Agency's Regulation I, Section 3.17 and RCW 43.21B.310, this Order may be appealed to the Pollution Control Hearings Board (PCHB). To appeal to the PCHB, a written notice of appeal must be filed with the PCHB and a copy served upon Puget Sound Clean Air Agency within 30 days of the date the applicant receives this Order.



626921


# Order of Approval for NC No. 9769

FEB 12 2008



Gerry Pade  
Reviewing Engineer

ns



Steven Van Slyke  
Supervising Engineer